

Polychlorinated Biphenyls (PCBs) Report

mod EPA Method 8082a¹Public Service of New Mexico
COUNTY ROAD 6800WATERFLOW, NM 87421 US
ATTN: KEN LACASSE
PO#: KEN LACASSE
Customer ID: TSNJM1Order#: 685522
Account: 822
Received: 09/26/2022
Reported: 10/07/2022
Project ID:

Lab Control #	Date Sampled	Sample Identification	Analyst ID	Date Analyzed	Matrix	Results	PCB Aroclor	Reporting Limit
		Serial Number	Batch#	Date Extracted				
		Equipment Type	-----	-----				
7584812	09/15/2022	SAN JUAN GEN STA	JA	10/03/2022	MIN	< 1.0 mg/kg	ND	1.0
		C-04759-5-1	2209	10/03/2022				
		TRANSFORMER	-----	-----				
Comment:								
7584813	09/15/2022	UNIT 2 MAIN TRANS	JA	10/03/2022	MIN	< 1.0 mg/kg	ND	1.0
		7001800	2209	10/03/2022				
		TRANSFORMER	-----	-----				
Comment:								
7584814	09/15/2022	SAN JUAN GENERATING STATION	JA	10/03/2022	MIN	< 1.0 mg/kg	ND	1.0
		7002474	2209	10/03/2022				
		TRANSFORMER	-----	-----				
Comment:								
7584815	09/15/2022	SJ PLANT	JA	10/05/2022	MIN	< 1.0 mg/kg	ND	1.0
		7002479	2209	10/05/2022				
		TRANSFORMER	-----	-----				
Comment:								
7584816	09/15/2022	SJ PLANT	JA	10/05/2022	MIN	< 1.0 mg/kg	ND	1.0
		C-04758-5-1	2209	10/05/2022				
		TRANSFORMER	-----	-----				
Comment:								
7584817	09/15/2022	SJ PLANT	JA	10/05/2022	MIN	< 1.0 mg/kg	ND	1.0
		RGP-3511	2209	10/05/2022				
		TRANSFORMER	-----	-----				
Comment:								
7584818	09/15/2022	SAN JUAN GENERATING STATION	JA	10/06/2022	MIN	< 1.0 mg/kg	ND	1.0
		M100638	2209	10/06/2022				
		TRANSFORMER	-----	-----				
Comment:								
7584819	09/15/2022	SAN JUAN GENERATING STATION	JA	10/06/2022	MIN	< 1.0 mg/kg	ND	1.0
		H882926B	2209	10/06/2022				
		TRANSFORMER	-----	-----				
Comment:								

Notations: - mg/kg , µg/g, µg/mL, µL/L = ppm, µg/L = ppb. Solids units are per dry weight. Quality control documentation is available upon request.

Notations: 1. Analysis is ISO/IEC 17025:2017 accredited, ANAB Accredited Certificate Number L2303.05 2. This test is conducted by a subcontracted laboratory. 3. Subcontracted laboratory has received ISO Standard 17025 accreditation for this test. 5. This test is conducted by Weidmann Laboratory other than Primary Lab. 6. Weidmann Laboratory has received ISO Standard 17025 accreditation for this test. 7. Imported Sample: WEIDMANN Electrical Technology accepts no responsibility for these results; accreditation status does not apply to these results. 8. Imported Equipment

Accreditation applies to current analysis only. The analyses, opinions or interpretations contained in this report are based upon material and information supplied by the client. WEIDMANN Electrical Technology does not imply that the contents of the sample received by this laboratory are the same as all such material in the environment from which the sample was taken. Our test results relate only to the sample or samples tested. Any interpretations or opinions expressed represent the best judgment of WEIDMANN Electrical Technology. WEIDMANN Electrical Technology assumes no responsibility and makes no warranty or representation, expressed or implied as to the condition, productivity or proper operation of any equipment or other property for which this report may be used or relied upon for any reason whatsoever. This test report shall not be reproduced except in full, without written approval of the laboratory.

Polychlorinated Biphenyls (PCBs) Report
mod EPA Method 8082a¹

Public Service of New Mexico
COUNTY ROAD 6800

WATERFLOW, NM 87421 US
ATTN: KEN LACASSE
PO#: KEN LACASSE
Customer ID: TSNJM1

Order#: 685522
Account: 822
Received: 09/26/2022
Reported: 10/07/2022
Project ID:

Lab Control #	Date Sampled	Sample Identification	Analyst ID	Date Analyzed	Matrix	Results	PCB Aroclor	Reporting Limit
		Serial Number	Batch#	Date Extracted				
		Equipment Type	-----	-----				

End of Test Report

Authorized By: 
JAWIED ANWAR
SENIOR CHEMIST

Notations: - mg/kg , µg/g, µg/mL, µL/L = ppm, µg/L = ppb. Solids units are per dry weight. Quality control documentation is available upon request.

Notations: 1. Analysis is ISO/IEC 17025:2017 accredited, ANAB Accredited Certificate Number L2303.05 2. This test is conducted by a subcontracted laboratory. 3. Subcontracted laboratory has received ISO Standard 17025 accreditation for this test. 5. This test is conducted by Weidmann Laboratory other than Primary Lab. 6. Weidmann Laboratory has received ISO Standard 17025 accreditation for this test. 7. Imported Sample: WEIDMANN Electrical Technology accepts no responsibility for these results; accreditation status does not apply to these results. 8. Imported Equipment

Accreditation applies to current analysis only. The analyses, opinions or interpretations contained in this report are based upon material and information supplied by the client. WEIDMANN Electrical Technology does not imply that the contents of the sample received by this laboratory are the same as all such material in the environment from which the sample was taken. Our test results relate only to the sample or samples tested. Any interpretations or opinions expressed represent the best judgment of WEIDMANN Electrical Technology. WEIDMANN Electrical Technology assumes no responsibility and makes no warranty or representation, expressed or implied as to the condition, productivity or proper operation of any equipment or other property for which this report may be used or relied upon for any reason whatsoever. This test report shall not be reproduced except in full, without written approval of the laboratory.