

LAKELAND, FL 33810 US

WEIDMANN ELECTRICAL TECHNOLOGY

3430 PROGRESS DRIVE, UNIT B + BENSALEM, PA + 19020

215 639 8599 + 215 639 8577 WWW.WEIDMANN-ELECTRICAL.COM REVISED TEST REPORT 01-7516650-669243-01

Reported: 01/26/2022

Page 1 of 2

Tampa Armature Works Serial#: C-03319-5-1 Mfr: MCGRAW EDISON Control#: 7516650

Location: BIG BEND 2 kV: 825 Order#: 669243

Equipment: TRANSFORMER kVA: 480000 Account: 614

Compartment: MAIN(BOTTOM) Year Mf'd: Received: 01/21/2022

ATTN: LUKE DAHLBERG

Breathing: SEAL

Syringe ID: 3001819

PO#: 40410626-1

Bank: Phase: 3

Bottle ID:

Duval Pentagons Diagnostic not applicable - Gas levels normal

Resampling Protocol Routine Screening

Weidmann Resampling Resample within 1 year.

Recommendation

Cellulose insulation CO and CO2 levels are normal. No indication of a fault involving paper.

PO#: 40410626-1		Bank:	Phase: 3	hase: 3			
Project ID: 40314260		Fluid: MIN	JSGal : 14100		Sampled By: R ASSESSOR		
Customer ID: GSU-2							
		Lab Control Number	: 7	516650			
		Date Sampled	: 01/0	05/2022			
		Order Number	:	669243			
		Oil Temp	:				
Dissolved Gas Analysis (DGA) O2/N2 Ratio:			:	0			
ASTM			: Ur	nknown			
D-3612 ¹	Hydrogen (H2) (μL/L):		1	<2			
Methane (CH4) (μL/L):				3			
Ethane (C2H6) (μL/L):			1	2			
Ethylene (C2H4) (μL/L):			1	<1			
Acetylene (C2H2) (μL/L):			1	<1			
Carbon Monoxide (CO) (μL/L):			1	9			
Carbon Dioxide (CO2) (µL/L):			1	225			
Nitrogen (N2) (μL/L):			1	66774			
Oxygen (O2) (µL/L):			:	<500			
		Dissolved Gas A	Analysis Dia	gnostics – IEEE	Std C57.104-201	19	
	Absolu	ıte Gas Levels (μL/L)	Gas Level D (2 most rece			Gas Generation Rates (µL/L per yr) (3-6 most recent samples within 4-24 mos.	
Gas	Level	Diagnostic	Delta	Diagı	nostic	Rate	Diagnostic
Hydrogen (H2)	<2	Normal (<= 80)					
Methane (CH4)	3	Normal (<= 90)					
Ethane (C2H6)	2	Normal (<= 90)					
Ethylene (C2H4)		Normal (<= 50)					
Acetylene (C2H2)		Normal (<= 1)					
Carbon Monoxide (CO)	9	Normal (<= 900)					
Carbon Dioxide (CO2)	225	Normal (<= 9000)					
DGA Diagnostics		Diagnostic not applicable - Gas levels normal.					
Duval Triangles Diagnostic not applicable – Diagnostic not applicable – Diagnostic not applicable –			- Triangle 4	gas levels norm	al.		

Comment:

General Oil Quality (GOQ)

Notations: 1. Analysis is ISO/IEC 17025:2017 accredited, ANAB Accredited Certificate Number L2303.02 2. This test is conducted by a subcontracted laboratory. 3. Subcontracted laboratory has received ISO Standard 17025 accreditation for this test. 5. This test is conducted by Weidmann Laboratory other than Primary Lab. 6. Weidmann Laboratory has received ISO Standard 17025 accreditation for this test. 7. Imported Sample: WEIDMANN Electrical Technology accepts no responsibility for these results, accreditation for this test. 7. Imported Sample: WEIDMANN Electrical Technology accepts no responsibility for these results, accreditation for this test. 7. Imported Sample: WEIDMANN Electrical Technology accepts no responsibility for these results, accreditation for this test. 7. Imported Sample: WEIDMANN Electrical Technology accepts no responsibility for these results, accreditation for this test. 7. Imported Sample: WEIDMANN Electrical Technology accepts no responsibility for these results, accreditation for this test. 7. Imported Sample: WEIDMANN Electrical Technology accepts no responsibility for these results, accreditation for this test. 7. Imported Sample: WEIDMANN Electrical Technology accepts no responsibility for these results, accreditation for this test. 7. Imported Sample: WEIDMANN Electrical Technology accepts no responsibility for these results, accreditation for this test. 7. Imported Sample: WEIDMANN Electrical Technology accepts no responsibility for these results, accreditation for this test. 7. Imported Sample: WEIDMANN Electrical Technology accepts no responsibility for these results, accreditation for this test. 7. Imported Sample: WEIDMANN Electrical Technology accepts no responsibility for these results. 8. Imported Sample: WEIDMANN Electrical Technology accepts no responsibility for these results. 8. Imported Sample: WEIDMANN Electrical Technology accepts no responsibility for these results. 8. Imported Sample: WEIDMANN Electrical Technology accepts no responsibility for these results. 8. Impor

DGA Status | Status | 1 - Normal gas levels and no Indication of gassing. Continue routine DGA and normal transformer operation.

Accreditation applies to current analysis only. The analyses, opinions or interpretations contained in this report are based upon material and information supplied by the client. WEIDMANN Electrical Technology does not imply that the contents of the sample received by this laboratory are the same as all such material in the environment from which the sample was taken. Our test results relate only to the sample or samples tested. Any interpretations or opinions expressed represent the best judgment of WEIDMANN Electrical Technology. WEIDMANN Electrical Technology assumes no responsibility and makes no warranty or representation, expressed to implied as to the condition, productivity or proper operation of any equipment or other property for which this report may be used or relied upon for any reason whatsoever. This test report shall not be reproduced except in full, without written approval of the laboratory.



LAKELAND, FL 33810 US

WEIDMANN ELECTRICAL TECHNOLOGY

3430 PROGRESS DRIVE, UNIT B + BENSALEM, PA + 19020

215 639 8599 + 215 639 8577 WWW.WEIDMANN-ELECTRICAL.COM 01-7516650-669243-01

Page 2 of 2

Tampa Armature Works Serial#: C-03319-5-1 Mfr: MCGRAW EDISON Control#: 7516650

Location: BIG BEND 2 kV: 825 Order#: 669243

Equipment: TRANSFORMER kVA: 480000 Account: 614

Compartment: MAIN(BOTTOM) Year Mf'd: Received: 01/21/2022

Project ID: 40314260 Fluid: MIN USGal: 14100 Sampled By: R ASSESSOR

Project ID: 40314260 Fluid: MIN USGai: 14100 Sampled By: R ASSESSOR

Customer ID: GSI	J-2						
	Lab C	ontrol Number:	7516650				
		Date Sampled:	01/05/2022				
		Order Number:	669243				
		Oil Temp:					
ASTM D-15331	Moisture in Oil	(mg/kg):	2				
ASTM D-9711	Interfacial Tension	(mN/m):	37.2				
ASTM D-9741	Acid Number	(mg KOH/g):	0.032				
ASTM D-15001	Color Number	(ASTM):	L3.0				
ASTM D-15241	Visual Exam.	(Relative):	PASS				
			CLR&BRIGHT				
ASTM D-15241	Sediment Exam.	(Relative):	ND				
ASTM D-877 1	Dielectric Breakdown (kV):		44				
ASTM D-9241	Power Factor @ 25°C (Rou	tine) (%):	0.035				
ASTM D-40521	Density @15°C	(g/mL):	0.8842				
GOQ Diagnostics Moisture in Oil:			Acceptable for in-se	rvice oil (20 mg/kg max).			
PER IEEE C57.106-2015 Interfacial Tension:			Acceptable for in-service oil (32 mN/m min).				
(most recent sample) Acid Number:		Acceptable for in-service oil (0.1 mg KOH/g max).					
Color Number and Visual:			Diagnostic not applicable. Diagnostic not applicable.				
Dielectric Breakdown ASTM D-877:			Diagnostic not applicable.				
Power Factor @ 25°C (Routine):			Acceptable for in-service oil (0.5% max).				
Comment:							
PCB	Concen	tration (mg/kg):	< 1.0 mg/kg				
mod EPA Method 8082a ^{5, 6} PCB Type (Arocolo		ype (Arocolor):	ND				
	F	Reporting Limit:	1.0				
Comment:							

End of Test Report

Authorized By:

ERIC MCANANY CHEMIST